









Instruction Manual Electronic Circuit Protector ESX10-TA/-TB-DC 24 V





Warning

This device is only suitable for operation at 24 VDC (safety extra-low voltage). Direct connection of this device to a 110 V, 230 V or 400 V power system, or to power systems with a higher voltage, may consequently result in death, severe personal injury or substantial property damage. Only qualified personnel should work on or around this equipment. The product will function correctly and safely only if it is transported, stored, set up and installed as intended.



Electrostatic sensitive devices (ESD) - the device must be opened only by the manufacturer.



Disposal guideline Packaging and packing aids can be recycled and should always be returned to use.

More detailed information can be obtained from local E-T-A subsidiaries or from the homepage www.e-t-a.de. The product is subject to technical modifications. In case of doubt the German text takes precedence. If used under Ex conditions, this device must only be actuated of the immediate environment is verifiably not classified as a hazardous area Automatic start-up of machinery after shut down must be prevented (Machinery Directive 2006/42/EG and EN 60204-1). In the event of a short circuit or overload the load circuit will be disconnected electronically by the ESX10-TA-/TB.

Installation instructions

The type ESX10-TA-/TB can be snapped onto symmetrical rail EN 60715.

Please observe the marking of the ESX10-T signal inputs and outputs. connection diagrams etc. Before power up the cables have to marked so as to prevent reverse polarity. The user should ensure that the cable cross sections of the relevant load circuit are suitable for the current rating of the ESX10-T used. In the event of Ex applications it has to be ensured that protection class IP 54 is achieved after installation in a UVprotected, fully enclosed room / control cabinet. IEC/EN60079-0 and IEC/ EN 60079-14 have be observed for installation.



 Safety
This device is not protected against reversed polarity of the input voltage. It has to be protected against overvoltage > 32 V. Danger of explosion: Incorrect connection of cables can cause ignition. The output and the device are protected by an internal, non-exchangeable blade fuse. Use in aggressive mixed media was not tested. When mounted side-by-side without convection, the devices should not carry more than 80 % of its rated load with 100 % ON duty due to thermal effects.

Table

Current rating (A)	0.5	1	2	3	4	6	8	10	12
Max. load (A)	0.5	1	2	3	4	5	7	9	10.8

Specifications:

opcomodation.							
Protection class	to EN60529 housing IP20, terminals IP20						
EMC	emitted interference to EN 61000-6-3 noise immunity to EN 61000-6-2						
Insulation coordination	0.5 kV / pollution degree 2, re-inforced insulation in operating area to IEC60934 / IEC60664						
CE logo	to 2014/30/EU and 2014/34/EU						
UL	UL 2367, File # E306740 Solid State Overcurrent Protectors UL 508, File # E322549 Industrial Control Equipment ISA 12.12.01-2015, File # E320024						
CSA	CSA C22.2 No: 14 File # 016186 CSA C22.2 No: 142 File # 016186 CSA C22.2 No: 213						
ATEX	IEC/EN60079-0 /-14/-15 (a) II 3G Ex nA II B T4 Gc X						

Ordering information

10 Electronic Circuit Protector, with current limitation

rail mounting, without signal contact

rail mounting, with aux, contact and hole for signal busbars/iumpers

standard, without physical isolation without signal input

with control input IN+ (only ESX10-T.-114) with reset input RE (only ESX10-T.-124, ESX10-T.-127)

without signal output (only ESX10-TA) signal contact N/O

signal contact N/C status output SF (only ESX10-T.-114. ESX10-T.-124)

inverse status output SF (only ESX10-T,-127)

DC 24 V rated voltage DC 24 V Current rating 0.5...12 A E ATEX

ESX10 -TB-1 0 1-DC 24 V-6 A -E Ordering information

1 Description

Electronic circuit protector type, ESX10-T is designed to ensure selective disconnection of DC 24 Vlad systems because it responds much laster to overlaad or short circuit conditions than the switch-most power supply. This is achieved by active current intratiation. The ESX10-T limits the highest possible current to 1.3 to 1.8 times the selected rated current of the circuit protector. Thus it is possible to switch or capacitive loads of up to 20,000 µF, but they are disconnected only in the event of an overlaad or short circuit.

For optimal alignment with the characteristics of the application the current rating of the ESX10-T can be selected in fixed values from 0.5 A..12 A. Falure and status indication are provided by a multicolour LED and an integral short-circuit-proof status output or a potential-free signal contact. Remote operation is possible by means of a remote reset signal or a remote ON/OFF control signal. The manual ON/OFF button allows separate actuation of individual load circuits.

Upon detection of overload or short circuit in the load circuit, the MOSFET of the load output will be blocked to interrupt the current flow. The load circuit can be re-activated via the remote electronic reset input, control input or manually by means of the ON/OFF button.

2 Technical Data (Tambient = 25 °C, US = DC 24 V)

Operating data						
Operating voltage U _s	DC 24 V (1832 V)					
Current rating I _N	0.5 A, 1 A, 2 A, 3 A, 4 A, 6 A, 8 A, 10 A, 12 A					
Closed current I ₀	ON condition: typically 2030 mA depending on signal output					
Status indication by means of	*multicolour LED: Green: - unit is ON, power-MOSFET is switched or is switched or - status output SF ON, supplies + DC 24 V Orange: - unit electronic disconnection Red: - unit electronically disconnected - unit electronically disconnected - load circuit/Power-MOSFET OFF OFF: - manually switched off (S1 = OFF) or device is dead - device is device is device is device is dead - device is device i					
Load circuit						
Load output	Power-MOSFET switching output (high side switch)					
Overload disconnection	typically 1.1 x I _N (1.051.35 x I _N)					
Short-circuit current I _K	Active current limitation with $I_{limit} = typically 1.8/1.5/1.4/4.3 \times I_{N}$, $I_{limit} = typically 1.8/1.4/4.3 \times I_{N}$, $I_{limit} = typical$					
Trip characteristic	active current limitation (see table 1)					
Trip thresholds/trip times (t ₁ , t ₂) at overcurrent	1. threshold: at I _{load} > typically 1.1 x I _h I _{Load} : (I _{Load} see table 1) t ₁ = typically 3s. 2. threshold: at I _{load} = I _{Load} : t ₁ = typically 100 ms3 s.					
Temperature disconnection	internal temperature monitoring with electronic disconnection					
Low voltage monitoring load output	with hysteresis, no reset required load "OFF" at U _s < 8 V					
Starting delay t _{start}	typically 0.5 sec after every switch-on and after applying U _S					
Disconnection of load circuit	electronic disconnection					
Free-wheeling circuit	external free-wheeling diode recommended with inductive load					
Several load outputs must	t not be connected in parallel					
Status output SF	ESX10-T114/-124/-127					
Electrical data	plus-switching signal output, connects $\rm U_{\rm g}$ to terminal 12 of module 17plus nominal data: DC 24 V / max. Oz A (short circuit proof) status output is internally connected to GND with a 10 kOhm resistor					


2 Technical Data (Tambient = 25 °C, Us = DC 24 V)


Status OUT	ESX10-TB-114/-124 (signal status OUT), at U $_{\rm S}=+24$ V $_{\rm S}=51$ is ON, load output connected through 0V $_{\rm S}=51$ is ON, load output blocked and/or switch S1 is OFF red LED lighted					
Status OUT	ESX10-TB-127 (signal status OUT inverted), at U _B = $+24$ V at U _B = $+24$ V = S1 is ON, load output locked red LED lighted 0 V = S1 is ON, load output connected and/ or switch S1 is OFF.					
OFF condition	0 V level at status output when: • switch S1 is in ON position, but device is still in switch-on delay • switch S1 is OFF, or control signal OFF, device is switched off • no operating voltage U _S					
Signal output F	ESX10-T101/-102					
Electrical data	potential-free signal contact max. DC 30 V/0.5 A, min. 10 V/10 mA					
ON condition LED green	oltage U _s applied, switch S1 is in ON position no overload, no short circuit					
OFF condition LED off	device switched off (switch S1 is in OFF position) no voltage U _s applied					
Fault condition LED orange	overload condition > 1.1 x I _N up to electronic disconnection					
Fault condition LED red	electronic disconnection upon overload or short circuit					
ESX10-TB-101	single signal, make contact contact SC/SO-SI open					
ESX10-TB-102	single signal, break contact contact SC/SO-SI closed					
Fault	signal output fault conditions: • no operating voltage U _s • ON/OFF switch S1 is in OFF position • red LED lighted (electronic disconnection)					
Reset input RE	ESX10-T124/-127					
Electrical data	voltage: max. + DC 32 V high > DC 8 V > DC 32 V low \$ DC 3 V > 0 V power consumption typically 2.6 mA (+DC 24 V) min. pulse duration typically 10 ms					
Reset signal RE terminal 22	The electronically blocked ESX10- TB-124/-127 may remotely be reset via an external momentary switch due to the fai- ling edge of a +24 V pulse. A common reset signal can be applied to several devices simultaneously. Switched on devices remain unaffected.					
Control input IN+	ESX10-T114					
Electrical data	see reset input RE					
Control signal IN+ terminal 21	+24V level (HIGH): device will be switched (terminal 21) on by a remote ON/OFF signal 0 V level (LOW): device will be switched off by a remote ON/OFF signal					
Switch S1 ON/OFF	unit can only be switched on with S1 if a HIGH level is applied to IN+					
LED display	ON: LED green / OFF: LED red					
General data						
Fail-safe element	backup fuse for ESX10-T not required because of the integral redundant fail-safe element					
Terminals screw terminals	LINE+/LOAD+/0V					

2 Technical Data (Tambient = 25 °C, US = DC 24 V)


Terminals	aux. contacts						
screw terminals max. cable cross section flexible with wire end ferru	ula w/wo plactic elagua	M3 0.25 – 2.5 mm ² 8 mm 0.5 - 0.6 Nm					
wire stripping length tightening torque (EN 609)							
Housing material	moulded						
Mounting	symmetrical rail to EN 60715-35x7.5						
Ambient temperature	0+50 °C (without condensation, see EN 60204-1)						
Storage temperature	-20+70 °C						
Humidity	96 hrs/95 % RH/40 °C to IEC 60068-2-78, test Calc climate class 3K3 to EN).					
Vibration	3 g, test to IEC 60068-2-6 test Fc						
Degree of protectio	housing: IP20 EN 60529 terminals: IP20 EN 60529						
EMC (EMC directive, CE logo)	emission: EN 61000-6-3 susceptibility: EN 61000-	6-2					
Insulation co-ordination (IEC 60934)	0.5 kV/2 pollution degree 2 re-inforced insulation in operating area						
dielectric strength	max. DC 32 V (load circu	it)					
Insulation resistance (OFF condition)	n/a, only electronic disco	nnection					
Dimensions (W x H x D)	12.5 x 80 x 83 mm						
Mass	approx. 65 g						

Schematic diagram ESX10-TB-124 (Example)





Time/Current characteristic curve (T_A = 25 °C)




- The trip time is typically 3 s in the range between 1.1 and 1.8 x I_N (e.g. ESX10-TB-...-6 A)
- - Without this current limitation a considerably higher overload current would flow in the event of an overload or short circuit.

Connection diagrams and application examples ESX10-T...

Signal contacts are shown in OFF or fault condition.


ESY10-TA-100

Single signalling with common reset



ESX10-TB-101

group signalling (series connection)



Application examples: line entry DC 24 V with

protection of signal circuit and direct connection of loads Auxiliary contacts are shown on the OFF of fault condition


FSX10-TR-101

ESY10-TR-124

Group signalisation (series connection)


Type FSX10-TA-100-DC24V-0.5A can be used as a

supply module including protection of auxiliary circuit Optional: Passive supply module AD-TX-EM01 (without protection)



ESX10-TB-102

Single signalling with common line entry



ESX10-TB-102


Single signalisation with common line entry Type ESX10-TA-100-DC24V-0.5A can be used as

a supply module

including protection of auxiliary circuit Optional: Passive supply module AD-TX-EM01 (without protection)

single signalisation per way by means of an LED LINE+ busbar (X 222 611 02 or X 222 611 xx) 0,5 A ESX10-TA-10 signal busbar (X 222 005 03) for common line entry @2 LO ₩3 0V 1⊗3 0V r⊗3 0V Ø3 0V Ø+Ø-

Mounting examples for ESX10-T



Mounting procedure:

Before wiring insert busbars into protector block. Max. 10 insertion/removal cycles for busbars.

Recommendation:

After 10 units the busbars and signal busbars should be interrupted and receive a new entry live

Table of lengths for busbars

(X 222 611 02 / X 222 005 03 or cut off, see accessories)

No. of units	2	3	4	5	6	7	8	9	10	
Length of busbar (mm) ± 0.5 mm	22	34.5	47	59.5	72	84.5	97	109.5	122	

3 Informationen on UL-approvals/ CSA-approvals

SX ESX10-TA / -TB

UL2367 Non-hazardoue uea III File # E306740

c**9X**us UL 508

Non-hazardous use UI File # F322549



(NO E322549

SX 12.12.01-2015 UL File # F320024

Operating Temperature Code T4

- This equipment is suitable for use in Class I, Division 2, Groups A, B, C and D or non-hazardous locations only. T4 A / 0 °C to 50 °C

WADNING

Exposure to some chemicals may degrade the sealing properties of materials used in the following device: relay (K1)

Sealant Material: Generic Name: Modified diglycidyl ether of bisphenol A Fine Polymers Corporation Epi Fine 4616L-160PK Supplier Type:

Casing Material: Generic Name: Liquid Crystal Polymer Supplier Sumitomo Chemical Type: E4008, E4009, or E6008

RECOMMENDATION:

Periodically inspect the device named above for any degradation of properties and replace if degradation is found

WARNING - EXPLOSION HAZARD:

AVERTISSEMENT - RISQUE D'EXPLOSION

- Do not disconnect equipment unless power has been removed or the area is known to be non-hazardous.
- Avant de deconnecter l'equipment, couper le courant ou s'assurer
- que l'emplacement est designe non dangereux.
- Substitution of any components may impair suitability for Class I, Division 2

La substitution de composants peut rendre ce materiel inacceptable pour les emplacements de class I, division 2.

This device is OPEN type equipment that must be used within a suitable end-use system enclosure, the interior of which is accessible only through the use of a tool. The suitability of the enclosure is subject to investigation by the local Authority Having Jurisdiction at the time

Wiring to or from this device, which enters or leaves the system enclosure, must utilize wiring methods suitable for Class I, Division 2 Hazardous Locations, as appropriate for the installation.

© ESX10-TA / -TB CSA C22.2 No: 14 - File # 016186 CSA C22.2 No: 142 - File # 016186 CSA C22 2 No: 213

(ESX10-T...-0.5 A / 1 A / 2 A / 3 A)

(Class I, Division 2) - File # 016186

Meets requirement for Class 2 current limitation

4 Accessories

4.1 Description

The ESX10-T features an integral power distribution system. The following wiring modes are possible with various pluggable current and signal busbars:

- LINE +(DC 24 V)
- Caution: The electronic devices ESX10-T require a
- 0 V connection signal contacts
- reset inputs

4.2 Accessories

Use original E-T-A accessories only!

Busbars for LINE+ and 0 V

may load with one line entry (recommended: centre line entry) max. load with two line entries grey insulation, length: 500 mm X 222 611 02

Busbars for LINE+ and 0 V

grey insulation max, number of plug-on operations 10:

X 222 611 22

(2-unit-block FSX10-T), length: 22 mm

X 222 611 34

(3-unit-block ESX10-T), length: 34.5 mm

X 222 611 47 (4-unit-block ESX10-T), length; 47 mm

X 222 611 59 (5-unit-block ESX10-T), length; 59.5 mm

X 222 611 72

(6-unit-block ESX10-T), length; 72 mm

X 222 611 97

(8-unit-block FSX10-T), length: 97 mm

X 222 611 12. (10-unit-block ESX10-T), length: 122 mm

Signal busbars for signal contacts and reset inputs

suitable for signal busbar ESX10-TB-... max. load with one line entry with one series connection of signal contacts I_{max} grey insulation, length: 500 mm X 222 005 03

Jumpers for signal contacts suitable for jumper ESX10-TB-. grey insulation, length: 21 mm X 222 005 13

Insulated wire bridge optional as jumper for ESX10-TB-101... for group signalisation (series connection) X 223 108 01

Connector bus link -K10

suitable for auxiliary contacts (series connection) X 210 589 02 (1.5 mm², brown)



E-T-A Elektrotechnische Apparate GmbH

EU-Konformitätserklärung Nr. 100.218.1018-04

Wir E-T-A Elektrotechnische Apparate GmbH

We Industriestraße 2-8, D-90518 Altdorf, Germany

(Name und Anschrift des Anbieters / supplier's name and address)

erklären in alleiniger Verantwortung, dass das Produkt declare under our sele responsibility that the product

Elektronischer Sicherungsautomat

ESX10-TA (Hutschlenenmontage 24Vdc / rail mounting 24Vdc)

ESX10-TB (Hutschienenmontage 24Vdc / rail mounting 24Vdc)

ESX10-... (Steckmontage, mit Modul 17PLUS, 24Vdc / plug-in mounting with module 17PLUS, 24Vdc)

Diese Konformitätserklärung folgt den grundlegenden Anforderungen der Norm EN ISONEC 17050-1/2010 Konformitätserklärungkonformitätserklärungvon Anbietern – Tell 1: Allgemeine Anforderungen.

en grundigeneten
eurogen der Noch
UREC 1705-)
UREC 1705-)
Umtätsbewertungmittalsenskans, auf das sich diese Erklärung bezieht, mit den wesentlichen

inhibitories—Tell*: and sixth greeke Envirolland policyland, in the environmental and das sixth greeke Envirolland (in the envirolland for the environment of the env

This Declaration of Coclourity is listensing the state of the standard bit of the stan

17080-12010 Oder normativen Dokumente herarar Conformity assessment -Supplier's declaration of conformity – Part 1: General requirements.

Explosionsgefährdete Bereiche - Teil 0: Betriebsmittel - Allgemeine Anforderungen

Explosion afmosphages - Pert 0: Explorent - General recurrencents

EN 60079-15: 2010 - Explosive Atmosphäre – Geräteschutz durch Zündschutzart "n" Explosive atmospheres – Equipment protection by type of protection "n"

(Titel und/oder Nr. sowie Ausgabedatum der Norm(en) oder der anderen normati- ven Dekumente / Title and /or number and date of issue of the standard(e) or other_normative document(s)

D-90518 Altdorf/bei Nürnberg • Germany • Telephone +49 9187 / 10-0 • Facsimile +49 9187 / 10-398

- 7 -



E-T-A Elektrotechnische Apparate GmbH

EU-Konformitätserklärung Nr. 100.218.1018-04 Declaration of Conformity

Zusätzliche Angaben: Additional information:

(II 3G Ex nA IIB T4 Gc X -20°C≤Ta≤+60°C (für/for ESX10-TC) 0°C≤Ta≤+50°C (für/for ESX10, ESX10-TA, ESX10-TB)

Besondere Bedingungen: Special conditions:

Die zugehörige Betriebsanleitung enthält wichtige sicherheitstechni-Line Zugernunge Betriebsanierung errinair wurzuge Sicherheitssechnische Hinweise und Vorschriffen für die Inbetriebnahme der genannten Geräte gemäß der Richtlinie 2014/34/EU (ATEX)

The perfinent ure manual is Including prinortet safely-safelar einkomannan and regulations for placing into operation of the described devices in accordance with Directive 2014/34/EU (ATEX).

Werden die Produkte in eine übergeordnete Maschine/Anlage eingebaut, so müssen die durch den Einbau entstehenden neuen Risiken durch den Hersteller der neuen Maschine/Anlage beurteilt werden.

In case the products will be fitted into a higher-level machine or system, the manufacturer the new machine or system needs to assess possible new risks resulting from this action.

Altdorf. 12. April 2017

Place and date of issue

Middle

rodukt-. Marktentwicklung

D-90518 Altdorf/bei Nürnberg • Germany • Telephone +49 9187 / 10-0 • Facsimile +49 9187 / 10-398

All dimensions without tolerances are for reference only. In the interest of improved design, performance and cost effectiveness the right to make changes in these specifications without notice is reserved. Product markings may not be exactly as the ordering codes. Errors and omissions excepted.



http://www.e-t-a.de/gr1006/

Bedienungsanleitung ESX10-TA/TB-.-E (D/E) Bestell-Nr. / Ref. number Y31040901 Index: b
Ausgabe / Issue: 10/2017 / Alle Rechte vorbehalten / All rights reserved



E-T-A Elektrotechnische Apparate GmbH Industriestraße 2-8 · 90518 ALTDORF GERMANY Phone: +49 9187 10-0 · Fax +49 9187 10-397 E-Mail: info@e-t-a.de · www.e-t-a.de